

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

No General Comments Available

Email Address(es): jfernandez3@dadeschools.net;
IPalacio@dadeschools.net;
JWare@dadeschools.net;
jaybolton@dadeschools.net;

Violations Comments

Violation #5. Maintenance & Repair

Observe stain ceiling tiles in room 53. Replace ceiling tile.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

Observe lights out in room 14 and 53. Replace light.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Violation #7. Heating, Ventilation, A/C Standards

Observe HVAC vents in rooms 26-bathroom and 14-bathroom with a buildup of dust. Clean and disinfect HVAC vents.

CODE REFERENCE: 7. Heating, Ventilation, A/C Standards. 5(14)(b)(12) SREF. Heating/Ventilation/Air Conditioning systems shall be operational. The systems shall maintain design temperatures of at least 78° F in the summer and 68° F in the winter; and shall provide adequate humidity control. There shall be no signs of mold or mildew on carpet or walls in or around the HVAC system or toilet rooms. 5(16)(a) SREF. All occupied rooms and other rooms where odors or contaminants are generated shall be provided with ventilation.

Violation #14. Soap Dispensers

Observe no soap in rooms 32 and 32. Replace soap.

CODE REFERENCE: 14. Soap Dispensers. 468.3.5.7.2 FBC. Soap dispensers for liquid, foam or powdered soap shall be provided at all handwashing basins. 5(10)(f) SREF. Dispensers for liquid, foam, or powdered soap shall be maintained in a safe & secure condition at all times.

Inspection Conducted By: Marcia Braithwaite (027326)

Inspector Contact Number: Work: (305) 623-3500 ex.

Print Client Name:

Date: 4/1/2019

Inspector Signature:

Marcia Braithwaite

Client Signature:

Jose Fernandez